

AMENDMENT NO. 1

This Amendment shall be for Request for Bid (RFB) for “AUTOMATIC WATER CONTROL GATES”

RFB is amended as follows:

- 1. Section V. Gate Specifications – Change: "All metallic components designed to operate near or below the waterline will be stainless steel and/or marine-grade aluminum. Components above the waterline are not required to be stainless steel but must have corrosion protection".**

- 2. Deadline for response – NO CHANGE**

Please complete the attached Acknowledgement of Receipt Form for this Amendment and return back by Tuesday June 25, 2024.

If you have any questions, please do not hesitate to contact me.

Richard DeLoia, Chief Procurement Officer
Middle Rio Grande Conservancy District
Phone: (505) 247-0234
E-mail: richard@mrgcd.us